

ZERTIFIKAT CERTIFICATE

Nr./No. 968/EZ 247.02/09

Prüfgegenstand Product tested	PROFIsafe V2 I/O - Modules	Hersteller Manufacturer	WAGO Kontakttechnik GmbH Hansastraße 27 32423 Minden Germany
Typbezeichnung Type designation	753-662 8 F-DI 753-667 4 F-DI / DO	Verwendungszweck Intended application	The PROFIsafe V2 I/O - Modules are 24VDC input / output devices for safety related applications
Prüfgrundlagen Codes and standards forming the basis of testing	IEC 61508 part 1-7:1998 - 2000 EN ISO 13849-1:2008 IEC 62061:2005 IEC 61131-2:2007 EN 50178:1997		
Prüfungsergebnis Test results	The PROFIsafe V2 I/O - Modules are suitable for safety related applications in accordance with IEC 61508 and IEC 62061 up to a Safety Integrity Level (SIL) 3 and EN ISO 13849-1 category 4, Performance Level (PL) e.		
Besondere Bedingungen Specific requirements	See test report-no.: 968/EZ 247.02/09 dated 2009-03-02, chapter 5, Summary		



Der Prüfbericht-Nr. 968/EZ 247.02/09 vom 02.03.2009 ist Bestandteil dieses Zertifikates.

Der Inhaber eines für den Prüfgegenstand gültigen Genehmigungs-Ausweises ist berechtigt, die mit dem Prüfgegenstand übereinstimmenden Erzeugnisse mit dem abgebildeten Prüfzeichen zu versehen.

The test report-no. 968/EZ 247.02/09 dated 2009-03-02 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorised to affix the test mark shown opposite to products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld AS!

Automation, Software und Informationstechnologie

Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln

2009-03-02

Datum/Date

Firmenstempel/Company stamp

Unterschrift/Signature

